

PRODUCT-DETAILS

TM10/12

TM10/12 Fail safe bell transformer



Informations générales

Extension du type de produit	TM10/12
Code de produit	2CSM228715R0802
EAN	8012542287155
Description courte	TM10/12 Fail safe bell transformer
Description longue	These transformers, with safety extremely-low voltage secondary (SELV), are suitable for driving loads that call for a discontinuous supply.

Technique

Normes et standards	IEC/EN 61558-2-8
Application	Residential
Primary Voltage	230 V
Secondary Voltage	(6-7) 4 V AC (5-6) 8 V AC (5-7) 12 V AC
Secondary Current	0.83 A
Output Current Maximum (I _{out})	2.5 A
Fréquence assignée (f)	50/60 Hz
Power Loss	2.5 W
Power Supply	10 V-A
Rated Output Power	10 W
Insulation Class	B
Tightening Torque	0.5 N-m
Transformer Type	Fail - Safe Bell Transformers

Options Provided	None
Remarks	Suitable for loads that require a discontinuous supply. Double insulation between primary and secondary windings
Connecting Capacity	2.5 mm ²

Environnement

Indice de protection	IP20
RoHS Status	Following EU Directive 2002/95/EC August 18, 2005 and amendment

Technique UL/CSA

Connecting Capacity UL/CSA	14 AWG
-------------------------------	--------

Dimensions

Width in Number of Modular Spacings	2
Produit Largeur Net	35 mm
Produit Hauteur Net	0.085 m
Produit Longueur Net	0.065 m
Poids net	0.300 kg
Produit Longueur Net	65 mm

Emballage

Emballage Niveau 1 Unités	box 6 pièce
Emballage Niveau 1 Largeur	0.09 m
Emballage Niveau 1 Hauteur	0.08 m
Emballage Niveau 1 Longueur	0.036 m
Emballage Niveau 1 Poids	2.1 kg
Emballage Niveau 1 EAN	8012542287162
Emballage Niveau 2 Unités	box 6 pièce
Emballage Niveau 2 EAN	8012542287162

Commande

Quantité minimum	1 pièce
Code douanier	85043121
Pays d'origine	Romania (RO)

Certificats et Déclarations (Numéro de document)

Certification Agency	IMQ
Déclaration de Conformité - CE	9AKK106713A5640
EAC Certificate	9AKK107992A6660
IMQ Certificate	9AKK107992A6765
Instructions et manuels	No document needed

Popular Downloads

Fiche produit, informations techniques	2CSC000001D0202
Instructions et manuels	No document needed

Classifications

ETIM 7	EC001547 - Bell transformer
ETIM 8	EC001547 - Bell transformer
Catégorie DEEE	5. Small Equipment (No External Dimension More Than 50 cm)
DEEE B2C / B2B	Business To Consumer
CN8	85043121
Object Classification Code	T

Catégories

Produits basse tension → Appareillage modulaire et parafoudres → Command and Signalling Devices → Bells and safety transformers

